



ई-मेल : ee\_rbi02\_@yahoo.com

# कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय उ0प्र0 जल निगम(ग्रामीण), अमेठी

फोन-9473942559

पत्रांक 2204

प्रयोगशाला 110 - / 34

दिनांक 24/5/2025

सेवा में,

The Principal

Mother Geeta

International School, Amethi

**विषय:-** पेयजल प्रमाण पत्र निर्गत कराये जाने के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय के पत्रांक 71273 दिनांक 22-02-2025 के संदर्भ में Mother Geeta International School, Amethi के लिये पेयजल से सम्बन्धित प्रमाण पत्र निर्गत करने का अनुरोध किया गया है।

उक्त के सम्बन्ध में विद्यालय द्वारा उपलब्ध कराये गये Submersible Pump के जल नमूनें की 14 पैरामीटर की जांच जनपद स्तरीय प्रयोगशाला उ0प्र0 जल निगम (ग्रामीण) अमेठी में की गयी, जिसमें पानी की गुणवत्ता संतोषजनक पायी गयी है।

**संगलनक:-** उपरोक्तानुसार।

भवदीय

अधिशासी अभियन्ता

पृ0सं0

/

/

दिनांक

प्रतिलिपि:-

1. सम्बन्धित सहायक अभियन्ता / जूनियर इंजीनियर (प्रयोगशाला) अमेठी।
2. खण्ड लेखाकार / मुख्य लिपिक / संगणक।

अधिशासी अभियन्ता



## Test Report

### DISTRICT LEVEL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM(Rural), AMETHI



TC-13416

Rept No.	Test Report/Exec Eng Con Divi /Chemical Test/ 361/2024-25	Issue Date	24/5/2025	Page No.	01
ULR NO	TC-134162500000039E				
Customer Details					
Office Name and Address	Mother Geeta International School, Amethi				
Ref Letter No & Date	School No - 71273 22-05-2025				
District	Amethi	Block	Amethi		
Gram Panchayat	Mahmoodpur	Village	Mahmoodpur		
Habitation	Mahmoodpur	Location	Near Mahila Polytechnic Amethi		
Water Source	Submersible Pump	Sample Code	A/22/05/1892		
Quantity of Sample	1.0 Liter	Date of Sample Collection	22-05-2025		
Receiving Date	22-05-2025	Sample Collector	Arvind Shrivastva		
Sample Depositer	Arvind Shrivastva	Sampling Method Used.	IS:17614:P-1:2021		
Analysis Start Date	23-05-2025	Analysis Completion Date	23-05-2025		

Environmental Condition		Temperature	25±3 oC	Humidity	50±15%
-------------------------	--	-------------	---------	----------	--------

S No	Parameter	Units	Observed Value	Technical Data of Analysis		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
				5	6	7
1	Turbidity	(NTU)	0.78	1.00	5.00	IS 3025 (Part 10) : 2023
2	pH Value		7.48	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022 (Electrometric Method)
3	TDS	(mg/L)	568	500.00	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	27.99	250.00	1000	IS 3025 (Part 32) : 2019
5	Iron (as Fe)	(mg/L)	0.5	0.30	1	APHA 24th Edition-3500-Fe Method B(Phenanthroline) 2023)
6	Sulphate (as SO4)	(mg/L)	11.26	200.00	400	APHA 24th Edition - 4500-SO4 Method E (Turbidity Method),2023
7	Nitrate (as NO3)	(mg/L)	1.44	45.00	45	APHA 24th Edition-4500-NO3 Method D(UV-Screening Method) 2023
8	Total Alkalinity(as CaCO3)	(mg/L)	222	200.00	600	IS 3025 (Part 23) : 2023
9	Total Hardness (as CaCO3)	(mg/L)	166	200.00	600	IS 3025 (Part 21) : 2019
10	Calcium	(mg/L)	20	75.00	200	IS 3025 (Part 40) : 2023
11	Magnesium	(mg/L)	28.188	30.00	100	IS 3025 (Part 46) : 2023
12	Taste	Qualitative	Agreeable	-	-	IS 3025 (Part 08) : 2023
13	Odour	Qualitative	Agreeable	-	-	IS 3025 (Part 05) : 2018
14	Colour	Hazen	BDL	5	15	APHA 24th Edition-2120 Colour Method B(Platinum Cobalts Visual

- Note:
- 1) This certificate refers only to the particular samples submitted for testing.
  - 2) This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
  - 3) The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  - 4) Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports.

*Neha Maurya*  
Prepared By  
Neha Maurya  
(Deputy Technical Manager)

*Chandra Prakash Sharma*  
Authorised signatory  
Chandra Prakash Sharma (Technical Manager)  
**Technical Manager**  
District Level Water Analysis Laboratory  
Amethi, UPJN

Laboratory Contact Details :- Name - Chandra Prakash Sharma  
Mo.No.- 9628474106

End of the report

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No.

Dated:

It is certified that an inspection team headed by Shri. Anshu Gupta (Assistant Engineer) (Name of Officers with designation) from U.P. Jal Nigam (Rural) PHED NABL inspected the **MOTHER GEETA INTERNATIONAL SCHOOL, LINK ROAD MAHMOODPUR INFRONT OF GOVT. GIRLS POLYTECHNIC, AMETHI** on 24-05-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. TC-134162500000039F dated 24-5-2025 of District level water analysis Lab, U.P. Jal Nigam (Rural), Amethi PHED NABL Lab) certified that the **MOTHER GEETA INTERNATIONAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 24-05-2025 to 23-05-2026

Signature with Seal: 

Name: (Shri. Anshu Gupta)

Designation: Assistant Engineer

Name & Address of the Office / Department:

U.P. Jal Nigam (Rural) Amethi  
(ग्रामीण) अमैठी

To

**MOTHER GEETA INTERNATIONAL SCHOOL**  
**LINK ROAD MAHMOODPUR**  
**INFRONT OF GOVT. GIRLS POLYTECHNIC,**  
**AMETHI- (U.P) 227405**

**Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies**